



**WATER QUALITY MONITORING UNIT
AMRIT BHAWAN, VINAY MARG, CHANAKYAPURI
QUALITY CONTROL & TECHNICAL AUDIT CELL
NEW DELHI MUNICIPAL COUNCIL
ISO 9001-2015 CERTIFIED**

SAMPLE NOT COLLECTED
BY UNIT STAFF

1. Name & Address of Sender:- Hos. Vidya Public School
2. Date of Receiving/Collection:- 07/08/2026
3. Sample No.:- 7899-7900
4. Sealed Sample (Yes/No):- Yes.

**DRINKING WATER TESTING REPORT
TEST-RESULTS**

Sr. No.	Location, Date & Time of Sample Collection Site	Colour (Pt-Co Scale)	Taste & Odour	Turbidity (NTU)	pH	Total Hardness (as CaCO ₃) (Mg/L)	TDS (Mg/L)	Iron (as Fe) (Mg/L)	Chloride (as Cl) (Mg/L)	Residual free Chlorine (Mg/L)	Coliform org. MPN / (100 ML)	E. Coli MPN / 100 ML
1. (A)	GIF water cooler	<5	agreeable	0.3	7.9	08	12	<0.02	02	0.2	NIL	—
2. (B)	First floor water cooler	<5	agreeable	0.4	7.8	28	40	<0.02	08	0.2	NIL	—
3.												
4.												
5.												
BIS: 10500 2012	Acceptable Limits	max 05	Agreeable	1 max.	6.5 To 8.5	200 max.	500 max.	1.0 max.	250 max.	0.2 min.	NIL	NIL
	Permissible Limits (in the absence of alternate source.)	15	Agreeable	5	No relaxation	600	2000	No relaxation	1000	1	NIL	NIL

Remarks: With respect to above tests, all the above water samples except Sr. No. _____ can/cannot be considered fit for drinking purposes. However minimum residual free chlorine 0.2 Mg/L should be done to avoid contamination.

10/08/2026
Bacteriologist

Chemist/Lab. Technician

10-08-26
Lab. Technician/Asstte.